

**First  
Environmental  
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

November 29, 2018

Mr. George Lambesis

**PIPER ELEMENTARY SCHOOL**

2435 Kenilworth Ave

Berwyn, IL 60402

Project/Site ID: Piper Elementary School

DCFS Provider ID: 06-016-1000-02

First Environmental File ID: 18-7031

Date Received: November 16, 2018

Dear Mr. George Lambesis:

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.


All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number 004324: effective 02/27/2018 through 02/28/2019.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or [firstinfo@firstenv.com](mailto:firstinfo@firstenv.com). More information can be found at [www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water](http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water).

Sincerely,

Lorrie Walker

Project Manager



**First  
Environmental  
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

**Analytical Report**

**Client:** PIPER ELEMENTARY SCHOOL  
**Project/Site ID:** Piper Elementary School  
**DCFS Provider ID:** 06-016-1000-02

**Date Received** 11/16/18  
**Date Reported** 11/29/18

**Total Metals**                      **Method: 200.8R5.4**  
**Analysis Date:** 11/28/18

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
18-7031-001	Gym fillstation South wall by main door	FDRW	11/16/2018 7:05	< 2.00
18-7031-002	Gym fillstation South wall by main door	FLSH	11/16/2018 7:06	< 2.00



## Chain of Custody Record for Lead Analysis School/Location Information Header

Complete the header information on this worksheet for each school building or separate ISBE ID. Replicate this sheet if necessary for additional buildings or ISBE ID numbers. Enter individual sample information on the worksheet labeled "Page 2".

Please complete all of the fields below that have been shaded in yellow. Complete the lilac shaded cells if the data report should go to someone other than the school contact.

School/Facility Information	
School/District Name:	Piper Elementary School
Address:	2435 Kenilworth Ave.
City/State/Zip:	Berwyn, IL 60402
School Contact:	George Lambesis
School Contact Phone:	(708) 303-4024
School Contact email:	glambesis@bsd100.org
ISBE ID:	06-016-1000-02
Building ID:	0001
Building Description:	Elementary School

Sample details are provided on the following sheets.

Client/Report Information	
If these samples were collected by an outside consultant for the school, please complete the following fields:	
Report to (Company Name):	South Berwyn School District 100
Report to (Name):	George Lambesis
Report to (e-mail):	glambesis@bsd100.org
Report to (phone):	(708) 303-4024

Sampling Information	
Sampled by:	Alex LeGare
Sampler Initials:	AL
Date Building Last Used:	11/15/18
Time Building Last Used:	10:15

Comments:

11/16/18 1310  
 11/16/18 1310

### Chain of Custody Record for Lead Analysis

**First Environmental Laboratories, Inc.**

Date Collected	Time Collected	Bottle No.	Field Sample ID	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
11/16/2018	7:05am	1	Gym fillstation	South wall by main door	fountain	first draw	250 mL	Lead 200.8	18-2021-001
	7:06am	2	Gym fillstation	South wall by main door	fountain	flush	250 mL	Lead 200.8	18-2021-002
		3					250 mL	Lead 200.8	
		4					250 mL	Lead 200.8	
		5					250 mL	Lead 200.8	
		6					250 mL	Lead 200.8	
		7					250 mL	Lead 200.8	
		8					250 mL	Lead 200.8	
		9					250 mL	Lead 200.8	
		10					250 mL	Lead 200.8	
		11					250 mL	Lead 200.8	
		12					250 mL	Lead 200.8	
		13					250 mL	Lead 200.8	
		14					250 mL	Lead 200.8	
		15					250 mL	Lead 200.8	
		16					250 mL	Lead 200.8	
		17					250 mL	Lead 200.8	
		18					250 mL	Lead 200.8	
		19					250 mL	Lead 200.8	
		20					250 mL	Lead 200.8	
		21					250 mL	Lead 200.8	
		22					250 mL	Lead 200.8	
		23					250 mL	Lead 200.8	
		24					250 mL	Lead 200.8	
		25					250 mL	Lead 200.8	

*[Signature]* 11/16/18 1310

*[Signature]* 11/16/18 1310